

# Environmental Laboratory of the Pacific

An Oceanic Analytical Laboratory

930 Mapunapuna Street, Suite 100 Honolulu, Hawaii 96819  
Telephone: (808)831-3090 Fax: (808)831-3098 E-mail: ELPacific@oceanic-labs.com

## Laboratory Report

Earth Technology Corp. (GU)  
790 S. Marine Dr., Suite 2A  
Tamuning, Guam 96931  
Attention: Todd Webster

Client Project ID: Production Well Project, 27556  
Sample Matrix/Description: Water, FTY-1  
Lab Sample ID: 99120595  
Work Order #: 9812172


Guam Sampled: Dec 22, 1999  
Hawaii Received: Dec 23, 1999  
Reported: Jan 4, 1999

### LABORATORY ANALYSIS

Analyte	Method	Units	Reporting Limit	Date Prepared	Date Analyzed	Sample Results
Chloride.....	EPA 325.2	mg/L	1.0	12/30/98	12/30/98	20
Fluoride.....	EPA 340.2	mg/L	0.020	12/29/98	12/29/98	N.D.
Hardness.....	SM 2340B	mg/L	50 a	1/4/99	1/4/99	220
pH.....	EPA 150.1	units	0.010	12/23/98	12/23/98	7.0
Specific Conductance.....	EPA 120.1	µmhos/cm	10	12/23/98	12/23/98	460
Turbidity.....	EPA 180.1	NTU	0.10	12/23/98	12/23/98	0.61

Analytes reported as N.D. were not present above the stated reporting limit.

E. L. PACIFIC

  
Kenneth K. F. Lee  
Laboratory Director

Please Note:

a MRL raised to achieve compound quantitation within the method calibration range.